



DEPARTMENT OF THE NAVY
NAVAL TRAINING CENTER
SAN DIEGO, CALIFORNIA 92133

AR_N00247_000100
NTC SAN DIEGO
SSIC NO. 5090.3.A

IN REPLY REFER TO:

5090

Ser 010/

2145

07 JUN 1993

PRODUCED AT GOVERNMENT EXPENSE

Ms. Vickie Church
County of San Diego
Environmental Health Services
Hazardous Material Management Division
P. O. Box 85261
San Diego, CA 92138-5261

Dear Ms. Church:

The purpose of this letter is to provide you with updated quarterly unauthorized release reports for case numbers T1717/H80010, T1542/H80021-003, and T1542/H80021-004 at Naval Training Center (NTC), San Diego.

Release #T1717/H80010 occurred at Building 344, Naval Exchange Gas Station, NTC. The contract to install a new vapor recovery system to correct a failed underground storage tank system test at the Naval Exchange Gas Station is in place. Swanson Products, Inc. will perform tests for tank tightness, pressurized piping system, and groundwater around tanks on June 8, 1993, before installing the new system. The contractor will also perform a line test for the pressurized piping system after installing the new system. Estimated completion date of the project is July 9, 1993, after which we will submit our progress report and test results to you.

Release #T1542/H80021-003 occurred at Building 227, NTC. Site assessment will be continued through 1993, possibly 1994, and a project to remove the contaminated soil at the site will start late 1994 or early 1995 as funds are available. There has been no other change in status since the last report.

Release #T1542/H80021-004 occurred at Building 344, Naval Exchange Gas Station, NTC. As you are aware, the skimming operation at monitoring well #4 has been discontinued because no free floating product had been recovered during previous months. In June 1993, we will obtain further samples to determine the amount of free floating petroleum product change since discontinuing the skimming operation.

NTC point of contact is Mr. Ed Chung at 524-0471.

Sincerely,

R. C. Citrano

R. C. CITRANO

Lieutenant Commander, U. S. Navy

Staff Civil Engineer

By direction of

the Commander

Copy to:

NEX

EFD SW (Code 18)

PRODUCED AT GOVERNMENT EXPENSE