



DEPARTMENT OF THE NAVY  
NAVAL TRAINING STATION  
SAN DIEGO, CALIFORNIA 92133-1000

AR\_N00247\_000297  
NTC SAN DIEGO  
SSIC NO. 5090.3.A  
UNCLASSIFIED REFERENCE

5090  
17/1212  
NOV 15 1990

Mr. John Menatti  
County of San Diego  
Environmental Health Services  
Hazardous Materials Management Division  
P. O. Box 85261  
San Diego, CA 92138-5261

Dear Mr. Menatti:

This letter is to provide you with updated Unauthorized Release reports for two underground storage tank sites at the Naval Training Center.

Release #T1542/H80021-004 is located at the Naval Exchange gas station, Building 344. As mentioned in our last report, a work plan for a site inspection is currently being prepared by contract under cognizance of the Southwestern Division Naval Facilities Engineering Command's (SWNAVFACENCOM) Installation Restoration program. The content of this plan, however, is contingent upon results of an investigation scheduled to begin in mid-December of three failed precision tank tests which occurred on the same site. Therefore, the work plan which was reported in our last update to be ready for review by December '90, will not be available until approximately sixty days after completion of this upcoming project. Updated reports on the suspected release due to the failed precision tests have been forwarded under case #T1717/H80010. The most recent updated report dated 26 October is attached.

Release #T1542/H80021-003 occurred at Building 227 NTC and is also under cognizance of the Southwestern Naval Facilities Engineering Command. Since our last report, a scope of work for the project has been completed under the Navy's CLEAN contract. Field work is scheduled to begin in January 1991.

The Naval Training Station point of contact is Ms. Martha Gandy, Environmental Engineer, at 524-1022. The SWNAVFACENCOM point of contact for release #T1542/H80021-004 is Mr. Jeff Kidwell (532-3152). The SWNAVFACENCOM point of contact for release #T1542/H80021-003 is Mr. Lance Smith (532-1581).

  
P. N. JOHNSON

Enclosure:  
Letter dtd 26 Oct. 1990, ser 1142

Copy to:  
NTC, San Diego  
→ SWNAVFACENCOM



DEPARTMENT OF THE NAVY  
NAVAL TRAINING STATION  
SAN DIEGO, CALIFORNIA 92133-1000

IN REPLY REFER TO:

5090  
17/ 1142  
OCT 26 1990

REPRODUCED AT GOVERNMENT EXPENSE

Ms. Mary Peters  
County of San Diego  
Department of Health Services  
Hazardous Materials Management Division  
1700 Pacific Highway  
San Diego, CA 92101-2417

Dear Ms. Peters:

The purpose of this letter is to update unauthorized release report #T1717/H80010 for four failed precision underground storage tank tests at Building 344, Naval Training Center.

Since our last report of July 20, 1990, Southwestern Division Naval Facilities Engineering Command has awarded task order 91 to the Comprehensive Long-Term Environmental Action Navy (CLEAN) contract. This work, awarded to Jacobs Engineering, Inc. includes investigating the source of the leaks, the testing of piping to pinpoint leaks, repair of leaks and/or replacement of piping, and final testing to prove tank system tightness. In addition, a monitoring system will be installed on the three 10,000 gallon tanks. The project is scheduled to be completed by March 31, 1991.

Naval Training Station point of contact is Ms. Martha Gandy, Environmental Engineer, at 524-1022.

Sincerely,

P. W. JOHNSON  
Captain, U. S. Navy  
Commanding Officer

Copy to:  
NTC San Diego  
SOUTHWESTERN DIVISION, NAVFAC  
NAVRESACT San Diego

ENCL (1)