

N00174.AR.000843
NSWC INDIAN HEAD
5090.3a

LETTER OF TRANSMITTAL AND MARYLAND DEPARTMENT OF THE ENVIRONMENT
COMMENTS ON FINAL EROSION AND SEDIMENT CONTROL PLAN AND STORMWATER
MANAGEMENT PLAN FOR SITE 21 BRONSON ROAD LANDFILL CLOSURE
CONSTRUCTION NSWC INDIAN HEAD MD
11/14/2011
MARYLAND DEPARTMENT OF THE ENVIRONMENT



MARYLAND DEPARTMENT OF THE ENVIRONMENT

1800 Washington Boulevard • Baltimore MD 21230

410-537-3000 • 1-800-633-6101 • www.mde.state.md.us

Martin O'Malley
Governor

Robert M. Summers, Ph.D.
Secretary

Anthony G. Brown
Lieutenant Governor

November 14, 2011

Mr. Joseph Rail, P.E.
NAVFAC Washington
Washington Navy Yard, Bld. 212
1314 Harwood Street SE
Washington, DC 20374-5018

Re: Final Erosion and Sediment Control Plan and Stormwater Management Plan Site 21 –
Bronson Road Landfill Closure Construction, Naval Support Facility Indian Head,
October 2011

Dear Mr. Rail:

The Federal Facilities Division of the Maryland Department of the Environment's Land Restoration Program has no comment on the above referenced document. This document was forwarded to the Water Management Administration's (MDE-WMA) Sediment and Stormwater Plan Review Division for review as well. Correspondence from MDE-WMA is enclosed.

If you have any questions, please contact me at (410) 537-3791.

Sincerely,

Curtis DeTore
Section Head
Federal Facilities Division

CD:cd

Enclosure

cc: Mr. Dennis Orenshaw
Mr. Horacio Tablada
Mr. James Carroll



MARYLAND DEPARTMENT OF THE ENVIRONMENT

MDE

1800 Washington Boulevard • Baltimore MD 21230
410-537-3000 • 1-800-633-6101

Martin O'Malley, Governor
Anthony G. Brown, Lieutenant Governor

Robert M. Summers, Ph.D., Secretary

Memorandum

TO: Mr. Curtis DeTore
Federal Facilities Division
Hazardous Waste Program
Waste Management Administration

FROM: Jim Tracy/MFL
Sediment and Stormwater Plan Review Division
Water Management Administration

DATE: October 28, 2011

Subject: MDE Plan Review No. **12-WM-0001**
Navy Support Facility Indian Head,
Site 21 Remedial Design,
Contract: N62470-08-D-1001

NOV 4 2011

CH2M Hill C.D.

The Water Management Administration (WMA) has reviewed the plans provided October 24, 2011 dated October, 2011 and prepared by ~~Tetra Tech NUS Inc.~~ for the above referenced project at the Naval Support Facility in Indian Head, Charles County, MD. The review was in accordance with Sections 4-106 and 4-205 of the Department of the Environment Article, Annotated Code of Maryland with regard to Sediment Control and Stormwater Management.

The proposed project plans submitted satisfy the substantive requirements for Stormwater Management and Erosion and Sediment Control.

The project meets the requirements for a type 3.3.B.1.b waiver of quantity control under the Stormwater Management Guidelines for State and Federal projects for Study points 1 and 3. Study point 2 will have a decrease in runoff. No impervious areas are proposed and there is a reduction in site impervious area. Therefore no water quality requirements apply. The attached Erosion and Sediment Control plan is acceptable.

Please call me at (410) 537-3563 with any questions or comments.

JKT/MFL

Attachment – Project Review File